



# INSPECTION REPORT

**Report Issued:** Oct 25, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPREL220316

**Issuance Date:** Mar 29, 2022

**Property Address:** 1859 RIVER QUEEN LN;

**Applicant:** RIDGELINE ELECTRIC LLC

**Contractor:** ALL JOEYS CONSTRUCTION INC POB 881524 STEAMBOAT SPRINGS, CO  
80488 (970) 531-1546

**To construct:** New Construction Residential

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** under ground electrical approved by Vince Grippa

**Corrections:**

Sincerely,

Heidi Spengler  
Sr Permit Tech  
hspengler@co.routt.co.us