



# INSPECTION REPORT

**Report Issued:** Oct 25, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL220761

**Issuance Date:** Jun 08, 2022

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Water pipe for all first floor units have been installed, supported and protected correctly from manifolds in corridor to fixtures. Pressure tests good at 100 psi for 15 minutes. Partial approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us