



INSPECTION REPORT

Report Issued: Oct 28, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220733

Issuance Date: Jun 06, 2022

Property Address:

Applicant: Mechanical & Piping Inc

Contractor: Mechanical & Piping Inc 6440 E. 50th Ave Commerce City, CO 80022 (303) 710-2869

To construct: New Restaurant and Rest room, Wild Blue Gondola Mid Mountain.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: In wall DWV and waterlines installed in Wild Blue Maintenance building All pipes properly supported, DWV test good at five psi waterlines good at hundred psi. Will inspect exposed plumbing at later inspection. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us