



# INSPECTION REPORT

**Report Issued:** Oct 28, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH221109

**Issuance Date:** Aug 08, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Deans Plumbing and Heating Inc

**Contractor:** Deans Plumbing and Heating Inc 192 East Line Street Bishop , CA 93514

**To construct:** Install boilers, overhead and underground snowmelt mains, snow field piping and manifolds

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas line installed from outside building to both boilers in mechanical room. Gas line properly supported and shut off valves installed. Gas line test is good at 15psi. Approved. Green Tag issued.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us