



INSPECTION REPORT

Report Issued: Nov 04, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: All hot and cold waterlines in lower level kitchen in promenade building installed to Approved Plans. All pipe are sized to plans and properly supported. Waterline passed 100psi test. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us