



# INSPECTION REPORT

**Report Issued:** Nov 07, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH221078

**Issuance Date:** Aug 03, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Griff Osman

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Above grid inspection completed for Ski Patrol area below promenade. All duct work and pipes installed and properly labeled. Air handling separated to work only in this space and not connected to rest of system until those areas are finalized. Partial approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us