



INSPECTION REPORT

Report Issued: Nov 14, 2022

Inspection Result: NOT READY

Permit Number: SPREL220471

Issuance Date: Apr 26, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: CENTRAL ELECTRIC, LLC

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: On Mountain/Greenhorn/Wild Blue Gondola
Install new circuitry, lighting, gear, mechanical.

On this day we have inspected your construction for **Electrical Temp Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Wrong inspection type requested

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us