



INSPECTION REPORT

Report Issued: Nov 15, 2022

Inspection Result: PASSED

Permit Number: SPRMH221409

Issuance Date: Sep 27, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: Boiler Flue, Hydronic Heat, Refrigeration, Duct Install, FCU Install

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Performed site final yesterday, all work was completed yesterday with the exception of the valves being installed in the mechanical unit in the closet, photos received of completed work with gauge installed holding pressure per the mechanical code, all work complete and approved.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us