



INSPECTION REPORT

Report Issued: Nov 18, 2022

Inspection Result: PASSED

Permit Number: SPREL221427

Issuance Date: Sep 30, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: CURRENT ELECTRICAL CONT.

Contractor: CURRENT ELECTRICAL CONT. 28395 cr 18 steamboat, CO 80487 (970) 846-1970

To construct: Green horn ranch chairlift and magic carpits on ski mtn.

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Permanent electrical service for snow making one and two located midpoint of greenhorn Express approved. Bonding of 400 amp disconnect and electrode attachment to be corrected.

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us