



INSPECTION REPORT

Report Issued: Nov 18, 2022

Inspection Result: **FAILED**

Permit Number: SPREL221427

Issuance Date: Sep 30, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: CURRENT ELECTRICAL CONT.

Contractor: CURRENT ELECTRICAL CONT. 28395 cr 18 steamboat, CO 80487 (970) 846-1970

To construct: Green horn ranch chairlift and magic carpits on ski mtn.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Upper greenhorn service will require engineered drawings and English instructions to show that lugs and disconnect are rated for two conductors and it wire sizes are appropriate. Service at lower greenhorn will require one 200 amp circuit that is separated into three conduits to be placed in one conduit and grounding electroconnection issues to be corrected and bonding of all enclosures on lower service.

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us