



# INSPECTION REPORT

**Report Issued:** Nov 21, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL220733

**Issuance Date:** Jun 06, 2022

**Property Address:**

**Applicant:** Mechanical & Piping Inc

**Contractor:** Mechanical & Piping Inc 6440 E. 50th Ave Commerce City, CO 80022 (303) 710-2869

**To construct:** New Restaurant and Rest room, Wild Blue Gondola Mid Mountain.

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Approval for service granted to install gas meter on maintenance building, but gas lines approved are to the Sprung Structure and the inspected heating equipment at the sprung structure, no gas appliances have been approved to be run at the maintenance building.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us