



# INSPECTION REPORT

**Report Issued:** Nov 29, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH221444

**Issuance Date:** Sep 29, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** All Purpose Mechanical

**Contractor:** Epic Construction Inc. 15334 E. Hinsdale Cir., Unit 1D Centennial, CO 80112  
(303) 840-8821

**To construct:** HVAC System and Temp Heat

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial; Bathroom exhaust fans installed and vented, 5 fan coil units properly installed and connected to existing ducts on lower level and 6 on main level. Ok to close grid ceiling on main level after passing electrical and fire inspections. Partial approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us