



INSPECTION REPORT

Report Issued:	Nov 30, 2022 Inspection Result: PASSED
	······································
Permit Number:	SPRRN221584
Issuance Date:	Nov 14, 2022
Property Address:	1865 SKI TIME SQUARE DR;
Applicant:	Calcon Constructors, Inc
Contractor:	Calcon Constructors, Inc 2270 W. BATES AVE. ENGLEWOOD, CO 80110 (720)
	930-7150
To construct:	Adding a door to the corridor of the existing office space and relocating one
	other office door due to the added corridor door

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 5/8 Type X drywall installed and properly fastened to both sides of partition wall. Approved, Good to tape and finish.

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us