



INSPECTION REPORT

Report Issued: Dec 06, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220733

Issuance Date: Jun 06, 2022

Property Address:

Applicant: Mechanical & Piping Inc

Contractor: Mechanical & Piping Inc 6440 E. 50th Ave Commerce City, CO 80022 (303) 710-2869

To construct: New Restaurant and Rest room, Wild Blue Gondola Mid Mountain.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: All plumbing in Sprung Structure completed. Water from tank is 140 degrees and tempered to 106 and all lavatories. Sprung good to TCO

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us