



# INSPECTION REPORT

**Report Issued:** Dec 06, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL221673

**Issuance Date:** Nov 09, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Griff Osman

**Contractor:** The TKM Group, LLC 10656 W. Glasgow Ave Littleton, CO 80127

**To construct:** UG/AG Plumbing

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: Under slab DWV for UC health space installed to revised plans on site. Submit these plans to RCRBD for approval, DWV test good at 5psi. Approved.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us