



INSPECTION REPORT

Report Issued: Dec 09, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220761

Issuance Date: Jun 08, 2022

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV lines installed correctly for bathroom groups, kitchen and laundry stacks for units 101-106 and 201-206. Just laundry and kitchen stacks for units 301-306, 401-406, 501-506. Pressure tests good at 5 psi for 15 minutes, still need to install nail plates. All second floor unit 1/2" water lines installed and supported correctly, pressure tests good at 100 psi, still need to install nail plates. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us