



INSPECTION REPORT

Report Issued: Dec 14, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and waterlines for level one promenade building kitchen and bathroom completed to Approved Plans. Waterlines passed test of 100psi and DWV passed 5psi hydrostatic test. All pipe are properly supported. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us