



INSPECTION REPORT

Report Issued: Dec 19, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: TB-21-835

Issuance Date: Apr 01, 2022

Property Address: 1859 RIVER QUEEN LN;

Applicant:

Contractor: Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

To construct: Work Description: Detached shared garage for duplex.

Permits for duplex are:

Unit A: B-21-755

Unit B: B-21-835

See B-21-755 for valuation and fees.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Roof and wall sheathing installed and properly fastened. Approved, Ok to cover walls

Corrections:

Sincerely,

Ron Norton
Inspector



rnorton@co.routt.co.us