



INSPECTION REPORT

Report Issued: Dec 21, 2022

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221078

Issuance Date: Aug 03, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Chiller lines completed to Approved Plans and passed pressure test of 100 psi from lower level to roof, final connections to roof unit still need to be made. Heat lines completed on main floor of promenade building to Approved plans and passed pressure test of 100psi. All pipes properly supported

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us