



# INSPECTION REPORT

**Report Issued:** Dec 27, 2022

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL220761

**Issuance Date:** Jun 08, 2022

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Units 401-409 and 501-509 DWV lines for bathroom groups have been installed and supported correctly. Pressure tests good for 15 minutes. partial approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us