



# INSPECTION REPORT

**Report Issued:** Jan 04, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL220761

**Issuance Date:** Jun 08, 2022

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Remaining DWV for bathroom groups in 4th and 5th floor in east apartments have been installed, supported and protected correctly. Pressure tests good at 5 psi for 15 minutes. Partial approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us