



INSPECTION REPORT

Report Issued:	Jan 05, 2023	Inspection Result:	PARTIAL PASS
		•	
Permit Number:	SPRPL220761		
Issuance Date:	Jun 08, 2022		
Property Address:	1901 CURVE PLZ;		
Applicant:	Bellyache Mechanical		
Contractor:	Bellyache Mechanical PO BO	DX 82 Wolcott , CO 816	55 (970) 470-3341
To construct:	Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas		

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 8 remaining tubs and P traps in units 413, 414, 513, 514 are holding water with no leaks detected.

Corrections:

Sincerely,

Silas Ebbert Inspector sebbert@co.routt.co.us