



INSPECTION REPORT

Report Issued: Jan 11, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220761

Issuance Date: Jun 08, 2022

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Units 310-314 water pipes have been installed correctly with pressure tests good at 100 psi for 15 minutes. Still need to install nail plates. Units 505-510 and units below club room vent PVC lines are installed correctly. Pressure tests good at 5 psi for 15 minutes. Approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us