



# INSPECTION REPORT

**Report Issued:** Jan 13, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL221673

**Issuance Date:** Nov 09, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Griff Osman

**Contractor:** The TKM Group, LLC 10656 W. Glasgow Ave Littleton, CO 80127

**To construct:** UG/AG Plumbing

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** DWV and waterlines installed to locations on approved Plans. All pipes are properly supported and protected. DWV passed test of 5psi and waterlines passed at 87psi. Approved, Ok to insulate pipes.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us