



INSPECTION REPORT

Report Issued: Jan 17, 2023

Inspection Result: PASSED

Permit Number: SPRNR221414

Issuance Date: Nov 09, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: The TKM Group, LLC

Contractor: The TKM Group, LLC 10656 W. Glasgow Ave Littleton, CO 80127

To construct: 1,228 square foot medical clinic.
Shell of warehouse already there.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All stud cavities have R-13 batt insulation installed. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us