



INSPECTION REPORT

Report Issued: Jan 23, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL210563

Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000 Holly Klein 12300 Pecos Street Westminster, CO 80234 (303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: DWV and waterlines run to locations on approved plans. All pipes are properly supported and protected. DWV test ids good at 7psi and waterlines are good at 100 psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us