



# INSPECTION REPORT

**Report Issued:** Jan 26, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRMH221674

**Issuance Date:** Nov 09, 2022

**Property Address:** 2305 MT WERNER CIR;

**Applicant:** Griff Osman

**Contractor:** The TKM Group, LLC 10656 W. Glasgow Ave Littleton, CO 80127

**To construct:** Mechanical Duct & Air Distribution

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Main trunk lines with required dampers, supply and return ducts installed Ducts are sealed and properly supported. Approved to insulate ducts. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us