



INSPECTION REPORT

Report Issued: Feb 01, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221674

Issuance Date: Nov 09, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: The TKM Group, LLC 10656 W. Glasgow Ave Littleton, CO 80127

To construct: Mechanical Duct & Air Distribution

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Supply and returns connected and sealed. Supply runs are insulated. Pending TAB report

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us