



INSPECTION REPORT

Report Issued: Feb 02, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221626

Issuance Date: Nov 02, 2022

Property Address: 1901 CURVE PLZ;

Applicant: Air Comfort, Inc.

Contractor: Deneuve Design, Inc dba Deneuve Consrt. Serv 2344 Spruce Strt Ste B
Boulder, Co 80302

To construct: Mechanical HVAC

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All duct work and dampers for 5th floor units have been installed, supported and sealed correctly. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us