



INSPECTION REPORT

Report Issued: Feb 10, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL221585

Issuance Date: Oct 25, 2022

Property Address: 1901 CURVE PLZ;

Applicant: CENTRAL ELECTRIC, LLC

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Steamboat basecamp
Temp power and new electrical for new building

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Interior reference 407 to 415 approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us