



INSPECTION REPORT

Report Issued: Mar 01, 2023 Inspection Result: PARTIAL PASS

Permit Number: SPRMH221165 Issuance Date: Aug 16, 2022

Property Address: 345 LINCOLN AVE, UNIT:205;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 6080 W 91ST CRT #2-104 WESTMINSTER, CO

80021

To construct: Modification of ductwork and installation of new hrv.

Kitchen hood venting

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All mechanical work completed except owner control center. HRV not operational at time of inspection but air handling does run. Good to TCO

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us