



INSPECTION REPORT

Report Issued: Mar 02, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221087

Issuance Date: Aug 03, 2022

Property Address: 1859 RIVER QUEEN LN;

Applicant: BB PLUMBING & HEATING

Contractor: BB PLUMBING & HEATING P.O. BOX 771102 STEAMBOAT SPGS, CO 80477
(970) 846-7331

To construct: in floor heat and bathroom fans

On this day we have inspected your construction for **Approval for Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Unit B hydronic tubing on main floor is installed, properly fastened and held 100psi for test duration. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us