



INSPECTION REPORT

Report Issued: Mar 14, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL220761

Issuance Date: Jun 08, 2022

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Basecamp affordable Housing Plumbing(Undergrounds, Rough and Trim, gas

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 1ST Floor Water Main from half way down north hall to east end has been installed, supported and protected correctly. Pressure test good at 100 psi for 15 minutes. partial approved

Corrections:

- 1 Building Department Corrections to be Completed
 1. Need to switch out copper support straps that are in contact with steel recirculation line support trays

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us