



INSPECTION REPORT

Report Issued: Mar 31, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221078

Issuance Date: Aug 03, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All welded connections on grease ducts inspected and approved. Will need to vapor test for leak at sensor location. All other duct approved to apply first layer of fire wrap.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us