



INSPECTION REPORT

Report Issued: Apr 03, 2023

Inspection Result: PASSED

Permit Number: SPRPL230298

Issuance Date: Mar 31, 2023

Property Address:

Applicant: rogelio A Castro

Contractor: unlimited plumbing solutions 1736 cimarron st Aurora, CO 80011

To construct: inside plumbing

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and waterlines run to locations on Approved Plans. All pipes are properly supported and protected. DWV test good at 6psi and waterlines at 90psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us