



INSPECTION REPORT

Report Issued: Apr 04, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH221078

Issuance Date: Aug 03, 2022

Property Address: 2305 MT WERNER CIR;

Applicant: Griff Osman

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New Mechanical for SPRNR220115

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Vapor test completed to fix last leak by sensor location this is approved. 2nd layer of fire wrap on grease duct completed but need to fix area that is cut at stud location and get clarification from CaptiveAir as to how far wrap need to go to top of curb. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us