



# INSPECTION REPORT

**Report Issued:** Apr 12, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL230305

**Issuance Date:** Apr 04, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Basecamp commercial space

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Subslab DWV lines for locker room and ADA bathroom groups have been installed and bedded correctly per approved plans. Pressure test good at 5 psi for 15 minutes. Approved to backfill.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us