



# INSPECTION REPORT

**Report Issued:** Apr 13, 2023

**Inspection Result:** PASSED

**Permit Number:** SPRDE220249

**Issuance Date:** Mar 30, 2022

**Property Address:** 2955 VILLAGE DR;

**Applicant:** Colorado Home Solutions

**Contractor:** Colorado Home Solutions 42440 FAWN WAY STEAMBOAT SPRINGS, CO  
80487 (970) 846-7346

**To construct:** Demo the interior of the KFMU building per the submitted plan

On this day we have inspected your construction for **Demolition Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Inspected the main level and 2nd level for 2-layers of type x 5/8" gypsum installed back to back between future residential units, drywall on main floor goes from top of sub floor to underside of subfloor on 2nd floor, then from top of 2nd floor subfloor to underside of roof deck. No assembly to view yet under demo permit, but this inspection is to note work done to date on these walls for future building permit

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us