

INSPECTION REPORT

Report Issued: Apr 17, 2023

Inspection Result: **FAILED**

Permit Number: SPRSW220508

Issuance Date: May 05, 2022

Property Address: 1901 CURVE PLZ;

Applicant: Deneuve Design, Inc dba Deneuve Consrt. Serv

Contractor: Eric Rehnberg - Deneuve Construction <NO STREET ADDRESS> CO Deneuve Design, Inc 2344 Spruce Strt Ste B Boulder, CO 80302 Eric Rehnberg 2344 Spruce St, Suit B Boulder, CO 80302 (303) 359-0276 Tate Tellier <NO STREET ADDRESS> CO

To construct: New 5 story multifamily building to replace the south half of existing building. New water sewer for new building. New water sewer stub outs for future phase. New drive lane to the east of existing structure. New storm lines and detention pond.

On this day we have inspected your construction for **45 Day Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

- 1 Continue to pick up trash at west side of site and north corner where snow storage piles still exist or where melted out.
- 2 Install rock socks around stockpiles.
- 3 Make available spill cleaned up materials at fueling station.

Sincerely,

Scott Slamal
Stormwater Inspector

P.O. Box 775088, Steamboat Springs, Colorado 80477-5088
970.879.2060 * 970.879.8851 (fax) * steamboatsprings.net



sslamal@steamboatsprings.net

P.O. Box 775088, Steamboat Springs, Colorado 80477-5088
970.879.2060 ✪ 970.879.8851 (fax) ✪ steamboatsprings.net