



INSPECTION REPORT

Report Issued: Apr 26, 2023

Inspection Result: PASSED

Permit Number: TB-21-755

Issuance Date: Sep 28, 2021

Property Address: 1859 RIVER QUEEN LN;

Applicant: Brstina LLC

Contractor: Brstina LLC P.O. BOX 883321 STEAMBOAT SPGS, CO 80488 (970) 846-4030

To construct: Construct new duplex and detached garage

Unit A: B-21-755

Unit B: B-21-834

Detached Garage: B-21-835

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Closed cell foam installed to 4 inches on all exterior walls and 3.5 inches applied to all concrete walls per Approved Plans. Plans amended to show insulation assemblies. Approved

Corrections:

Sincerely,

Ron Norton
Inspector



rnorton@co.routt.co.us