



INSPECTION REPORT

Report Issued: May 16, 2023 Inspection Result: PARTIAL PASS

Permit Number: SPRPL210563
Issuance Date: Nov 08, 2021

Property Address: 2305 MT WERNER CIR;

Applicant: MTech Mechanical Technologies Group

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co

80234 (719) 782-4000Holly Klein 12300 Pecos Street Wesminster, CO 80234

(303) 650-4000

To construct: Plaza/Promenade new plumbing UG and AG

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: floor drains in ski storage gridlines G and 2.1 installed and passed test of 6psi. Approved

Corrections:

Sincerely,

Ron Norton Inspector rnorton@co.routt.co.us