



INSPECTION REPORT

Report Issued: May 16, 2023

Inspection Result: NOT READY

Permit Number: SPRWD221468

Issuance Date: May 15, 2023

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: Trinity Contracting, Inc.

Contractor: Trinity Contracting, Inc. 304 Lilac Court Hayden, CO 81639

To construct: Removal and Re-installation of 5 windows and 1 door Torin Plum Condo Unit 205 Bldg A

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us