



INSPECTION REPORT

Report Issued: May 26, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH230596

Issuance Date: May 24, 2023

Property Address: 1800 BURGESS CREEK RD;

Applicant: JDW INC

Contractor: JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477 (970) 879-0642

To construct: UNIT 202 MINI SPLIT INSTALLATION

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2 Mini split heads and condenser installed. Line sets connected and passed pressure test of 550 psi. Condensate lines need to be run to outside and drain pipe repaired. Partial approved. Fix pipe and schedule reinspection.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us