



INSPECTION REPORT

Report Issued: May 30, 2023

Inspection Result: PASSED

Permit Number: SPRMH230620

Issuance Date: May 25, 2023

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: J & I Plumbing and Heating Services LLC

Contractor: J & I Plumbing and Heating Services LLC 1664 Yampa Ave Craig, CO 81325

To construct: 2 mini split heads

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: 2 line sets installed from condenser location on patio to head locations. Line sets supported and passed test of 250psi. Apparently

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us