



INSPECTION REPORT

Report Issued: Jun 06, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL230656

Issuance Date: Jun 05, 2023

Property Address: 2315 APRES SKI WAY;

Applicant: BLACK LAB ELECTRICAL LLC

Contractor: BLACK LAB ELECTRICAL LLC P O BOX 772768 STEAMBOAT SPRINGS, CO
80477 (970) 761-0458

To construct: New in ground pool and 2 hot tubs

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Pool bonds approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us