



# INSPECTION REPORT

**Report Issued:** Jun 07, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPO230539

**Issuance Date:** Jun 06, 2023

**Property Address:** 2315 APRES SKI WAY;

**Applicant:** MOUNTAIN POOLS & SPAS

**Contractor:** ELK COUNTRY RENOVATIONS LLC 625 COUNTY RD CRAIG, CO 81625 (970) 326-7024

**To construct:** Remove and replace one pool and two hot tubs no changes to mechanical rooms

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All rebar installed is sized and spaced correctly. Will need to cut off ends of rebar at top of form to create 1.5 inch clearance to outside of form. Circulation pipes installed for pool only and passed test of 35psi. Partial approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us