



INSPECTION REPORT

Report Issued: Jun 16, 2023

Inspection Result: PASSED

Permit Number: SPRRN230222

Issuance Date: Apr 19, 2023

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: GARCIA CONSTRUCTION LIMITED

Contractor: GARCIA CONSTRUCTION LIMITED 1153 OAK STREET STEAMBOAT SPRINGS,
CO 80477 (970) 757-3250

To construct: Remodel of lobby space. New storage room framing, replace existing fireplace unit, new exterior windows
4.19.23: PARTIAL APPROVAL FOR SELECTIVE DEMO- SEE LETTER "GARCIA PHASED APPROACH REQUEST LETTER.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Framing complete and walls insulated to existing R-Values reusing existing insulation. Windows insulated with sprayfoam. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us