



INSPECTION REPORT

Report Issued: Jun 22, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL230305

Issuance Date: Apr 04, 2023

Property Address: 1901 CURVE PLZ;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Basecamp commercial space

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line installed from mech room to meter and to roof top. Gas line is properly supported and passed test of 15psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us