



INSPECTION REPORT

Report Issued: Jun 28, 2023

Inspection Result: PASSED

Permit Number: SPRMH230483

Issuance Date: May 05, 2023

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: HOT STUFF HEARTH & HOME

Contractor: HOT STUFF HEARTH & HOME 1625 MID VALLEY DR #3 STEAMBOAT SPGS, CO
80487 (970) 879-7614

To construct: Gas Fireplace in Lobby

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: final approved, keyed valve on left side installed, unit fired and worked properly

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us