



INSPECTION REPORT

Report Issued: Jun 29, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH230780

Issuance Date: Jun 26, 2023

Property Address: 2315 APRES SKI WAY;

Applicant: ALPINE HEATING & SHEET METAL

Contractor: ALPINE HEATING & SHEET METAL P.O. BOX 770999 STEAMBOAT SPGS, CO
80477 (970) 879-2396

To construct: INSTALL 2,000 square feet of PEX FOR SNOW MELT SYSTEM FOR APRONS,
POOL, & SPAS

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Pool surround hydronic, complete and holding 100 psi, stapled to R-10 foam board

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us